| 4 | 3 | 2 | | 1 | |
|---------------------|---------------------------------------|---|------|--|---|
| | · · · · · · · · · · · · · · · · · · · | | ITEM | PART NUMBER | DESCRIPTION |
| | | | 1 | 258-40X100-XXX | 1" CIRCUITSOLVER THERMOSTATIC BALANCING VALVE W/INTEGRATED UNION |
| | | | 2 | 92-170 (QTY-2) | BALL VALVE, 1" MxF, LF |
| | | | 3 | 92-044 | 1" X CL NIPPLE BRS LF |
| | | | 4 | 93-178 | STRAINER, 1" Y, SS |
| | | | 5 | 93-174 | 1" X 1/2" TEE |
| | | | 6 | 93-094 | THERMOWELL |
| | <i>(</i> | | 7 | 94-287 | THERMOMETER |
| | | | 8 | 92-092 (QTY-2) | ADAPTER , 1" NPT x 1" PROPRESS |
| 8 2 Ø2.5 [64] | FLOW | | | 8 3.1 [79] 7 7 7 7 7 7 7 7 7 7 7 9 7 7 9 7 7 9 7 7 9 7 9 7 9 7 9 7 9 7 9 7 9 7 7 9 7 7 9 7 7 9 7 7 9 7 7 9 7 7 9 7 7 9 7 7 9 7 7 7 7 9 7 | |
| NOTES: | 19. [50 | 8 | | | |

Α

В

- Cv: OPEN: 3.3, CLOSED: 0.2, DESIGN: 1.57.
 WEIGHT: 8.4 Lbs (3.8 Kg).
 MAXIMUM WORKING PRESSURE: 200 PSIG (14 BAR).
 MAXIMUM WORKING TEMPERATURE: 250°F (121°C).
 XXX REFERS TO THE DESIRED CLOSING TEMPERATURE IN °F.
- 6. ALL COMPONENTS ARE NSF/ANSI 61 AND NSF 372 CERTIFIED
- IN DOMESTIC WATER SYSTEMS.

| IN DOMESTIC WATER SYSTEMS. | | | | | COMPONENT | CircuitSolver Union Stra with Thermometer & Vi | |
|--|--|--|---|--|--------------------------------|---|--------|
| ThermOmegaTech | are provided for reference and evaluation | This file and any associated information and specifications are provided for reference and evaluation purposes only, and is subject to change without notice. ThermOmegaTech makes no representations, warranties or guarantees as to the appropriateness, accuracy, completeness, or suitability for any purpose, of the file, information or specifications. You are solely responsible for the use of the file, information or specifications. | | This drawing is the property of ThermOmegaTech. It contains confidential, proprietary information that is ThermOmegaTech property. Do not disclose to or duplicate for others except as authorized by ThermOmegaTech. | | | |
| ThermOmegaTech, Inc. | and to subject to shange without house. The | | | | | | |
| 353 Ivyland Road Warminster, PA 18974-2205, USA Ph: 215-798-5978 | for any nurness of the file information or a | | | | | | |
| | Tou are solely responsible for the use | | | NTS | 1" - CSUAS-PP WITH THERMOMETER | | 1 of 1 |
| 4 | 3 | | 2 | | | 1 | |

В

А